



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312313000366

Applicant	Pflitsch GmbH & Co. KG
Address	Ernst-Pflitsch-Straße 1, 42499 Hückeswagen, Germany
Manufacturer	Pflitsch GmbH & Co. KG
Address	Ernst-Pflitsch-Straße 1, 42499 Hückeswagen, Germany
Production Factory	Pflitsch GmbH & Co. KG
Production Address	Ernst-Pflitsch-Straße 1, 42499 Hückeswagen, Germany
Product	Reducer
Model/Type	RED*****
Ex marking	Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da
Reference Standards	GB/T 3836.1-2021, GB/T 3836.2-2021, GB/T 3836.3-2021, GB/T 3836.31-2021

Certification mode Type Test + Initial Factory Inspection + Post-Certification Surveillance

The product(s) is verified and certified according to CNCA-C23-01: 2019 *China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product* and CNEX-C2301-2019 *Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product*.

See Annex for the detailed product information (4 pages).

Initial issue date: 2021-05-12

Issued date: 2023-07-20

Valid to: 2026-05-11

The validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the original Chinese version, the Chinese version shall prevail.

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co., Ltd.



<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China P.C.: 473008
Tel: 0377-63239734 Email: ccc@cn-ex.com

CN 0002028



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2021312313000366

Page 1 of 4

Product information:

1. This certificate covers the following models:

- RED*****

Nomenclature:

RED	*	*	*	*	*	*	*
1	2	3	4	5	6	7	8

1) Type

RED = Reducer

2) Type of connecting thread

2 = Metric

3 = NPT

3) Size of connecting thread (code number)

4) Size of second connecting thread of reducer (code number)

5) Material body

ms = brass

VA = stainless steel

6) EMC spring (optional)

- = no EMC spring

tri = with EMC spring

7) Explosion protection

Issued date: 2023-07-20

Director:

穆大玉



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co., Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2021312313000366

Page 2 of 4

Ex d = Type of protection Flameproof enclosure "d"

8) Additional letter for material and O-ring

V4A = stainless steel

bl = brass blank

Technical data:

Size of thread	M16 to M63 NPT 3/8" to NPT 2 1/2"
Suited for devices of equipment group II with mechanical risk level	High, 7J
Mounted in enclosures with clearance holes(For Ex e, Ex t)	
Plastic, wall thickness	≥2mm
Metal, wall thickness	≥1mm
Mounted in enclosures with threaded holes(For Ex e, Ex t)	
Plastic, wall thickness	≥5mm
Metal, wall thickness	≥3mm
Torque see manual	Depending on the nominal size Metric, NPT: 15 Nm to 80 Nm
Ambient temperatures	
Connecting O-ring	Silicone -60 °C to +130 °C

Issued date: 2023-07-20

Director:

穆大玉



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co., Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2021312313000366

Page 3 of 4

Ingress protection	IP66, IP68 (1h, 1MPa)
Service temperatures	-60 °C to +130 °C

Thread, metric	Thread, NPT	Torque	Min. Temperature, Overpressure
M16×1.5	NPT 3/8"	15 Nm	-60 °C / 4.86MPa
M20×1.5	NPT 1/2"	20 Nm	-60 °C / 4.86MPa
M25×1.5	NPT 3/4"	30 Nm	-60 °C / 4.86MPa
M32×1.5	NPT 1"	30 Nm	-60 °C / 4.86MPa
M40×1.5	NPT 1 1/4"	35 Nm	-60 °C / 4.86MPa
M50×1.5	NPT 2"	80 Nm	-60 °C / 4.86MPa
M63×1.5	NPT 2 1/2"	80 Nm	-60 °C / 4.86MPa

Ex marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da

- Producers should organize production in accordance with the technical documents approved by the certification body.

2. Specific conditions of safety use:

- When the reducer is built into an enclosure in the type of protection Flameproof enclosure "db", it is recommended to include them into the explosion tests of enclosure.

- See instruction for other information.

Issued date: 2023-07-20

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co., Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2021312313000366

Page 4 of 4

3. Certificate related report(s):

- Type test report: CQST2011C049, CQST2011C049/01
- Factory inspection report: CN2021Q010004

4. Certificate change information:

- 1st change on July 20, 2023: Updated the standards for certification.

Issued date: 2023-07-20

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co., Ltd.

