



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312313000363

Applicant Pflitsch GmbH & Co. KG
Address Ernst-Pflitsch-Straße 1, 42499 Hückeswagen, Germany
Manufacturer Pflitsch GmbH & Co. KG
Address Ernst-Pflitsch-Straße 1, 42499 Hückeswagen, Germany
Production Factory Pflitsch GmbH & Co. KG
Production Address Ernst-Pflitsch-Straße 1, 42499 Hückeswagen, Germany
Product Cable gland
Model/Type UNI Ex * Dicht Silicone *****
 UNI Ex Sleeve EMC Dicht Silicone *****
Ex marking Ex e IIC Gb, Ex tD A20 IP66/68
Reference Standards GB3836.1-2010, GB3836.3-2010, GB12476.1-2013,
 GB12476.5-2013

Certification mode Type Test + Initial Factory Inspection + Post-Certification Surveillance

The product(s) is verified and certified according to CNCA-C23-01: 2019 *China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product* and CNEC-C2301-2019 *Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product*.

See Annex for the detailed product information (6 pages).

Issued on: 2022-01-19

Valid to: 2027-01-18

The validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the original Chinese version, the Chinese version shall prevail.

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.



<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China
Tel: 0377-63239734

P.C.: 473008
Email: ccc@cn-ex.com

CN 0000985



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312313000363

Page 1 of 6

Product information:

1. This certificate covers the following models:

- UNI Ex * Dicht Silicone ***** and UNI Ex Sleeve EMC Dicht Silicone *****

Nomenclature:

UNI EX	*	Dicht Silicone	*	*	*	*	*	*	*	*	*	*	*	*
1	2	3	4	5	6	7	8	9	10	11	12	13	14	

- 1) Part of general type
- 2) Type edition (e.g. HF, IRIS)
- 3) Part of general type
- 4) Type edition (multiple metric, multiple Pg)
- 5) Type of connecting thread (2)
- 6) Size of connection thread
- 7) Size of head thread
- 8) Material (st = stainless steel, d = brass, nickel plated)
- 9) Kind of insert (i = silicone)
- 10) Sealing range
- 11) blank
- 12) blank
- 13) Explosion protected, "ex"

Issued on: 2022-01-19

Director:



**Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.**





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312313000363

Page 2 of 6

14) Additional letter (V4A, bl, tri)

Remark: variant numbers can be unoccupied

UNI EX	Sleeve EMC	Dicht Silicone	*	*	*	*	*	*	*	*	*	*
1	2	3	4	5	6	7	8	9	10	11	12	13

- 1) Part of general type
- 2) Type edition
- 3) Part of general type
- 4) Type edition (metric)
- 5) Size of connection thread
- 6) Size of head thread
- 7) Material (st = stainless steel)
- 8) Maximum cable diameter
- 9) Flexible spring = FBS
- 10) Kind of insert (i = silicone)
- 11) EMC connection = tri
- 12) Material of sealing insert = HTS
- 13) Explosion protected, "ex"

Remark: variant numbers can be unoccupied.

Technical data UNI Ex * Dicht Silicone ***** :

Issued on: 2022-01-19

Director:



**Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.**





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2021312313000363

Page 3 of 6

Size, Connection thread and head thread				Torque			Mechanical strength
metric	Pg	Inch	NPT	Conne- ction thread	Head thread	Clamping screw	--
M 12×1.5	Pg 7	G 1/4"	-	6 Nm	6 Nm	1 Nm	4J
M 16×1.5	Pg 9	G 3/8"	NPT 3/8"	6 Nm	6 Nm	1 Nm	4J
M 20×1.5	Pg 11 Pg 13.5	G 1/2"	NPT 3/8" NPT 1/2"	10 Nm	5 Nm standard 10 Nm flat cable	1 Nm	7J
M 25×1.5	Pg 16	G 3/4"	NPT 1/2"	10 Nm	10 Nm	1 Nm	7J
M 32×1.5	Pg 21	G 1"	NPT 3/4"	15 Nm	15 Nm	1 Nm	7J
M 40×1.5	Pg 29	G 1 1/4"	NPT 1"	20 Nm	20 Nm	1 Nm	7J
M 50×1.5	Pg 36	G 1 1/2"	NPT 1 1/4"	30 Nm	30 Nm	1 Nm	7J

Issued on: 2022-01-19

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2021312313000363

Page 4 of 6

Cable diameter	Round cable: 7.0 mm to 13.0 mm Flat cable: size 5.9 x 12.4 mm height = 5.3 to 5.9 mm width = 10.7 to 12.4 mm flat cable: size 7.4 x 13.0 mm height = 5.6 to 7.4 mm, width = 11.7 to 12.9 mm
Tensile force	Depends on the pressure screw used, low (25 % rule) or high
Mounted in enclosures with clearance holes Plastic, wall thickness	≥2 mm
Metal, wall thickness	≥1 mm
Mounted in enclosures with threaded holes Plastic, wall thickness	≥5mm
Metal, wall thickness	≥3mm
Service temperature	Insert for round: -55 °C to +160 °C Insert for flat cable: -40 °C to +130 °C
Ingress protection	IP66 and IP68 (1MPa, 30 min)

Technical data UNI Ex Sleeve EMC Dicht Silicone *****

Size of connection thread	M20 and M32
---------------------------	-------------

Issued on: 2022-01-19

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.



<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China
Tel: 0377-63239734

P.C.: 473008
Email: ccc@cn-ex.com



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312313000363

Page 5 of 6

Cable diameter	
Round cable insert	12.4 mm and 17.4 mm
Multiple cable insert	Min. diameter 2.1 mm Max diameter 3.9 mm
Suited for devices of equipment group II with mechanical risk level	High, 7 J
Tensile force	Low (25 % rule)
Torque	Size M20 Adapter coupling 10 Nm Pressure screw 5 Nm
	Size M32 Adapter coupling 20 Nm Pressure screw 15 Nm
Mounted in enclosures with clearance holes	
Plastic, wall thickness	≥2mm
Metal, wall thickness	≥1mm
Mounted in enclosures with threaded holes	
Plastic, wall thickness	≥5mm
Metal, wall thickness	≥3mm
Service temperature	-60 °C to +130 °C

Issued on: 2022-01-19

Director:



**Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.**





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2021312313000363

Page 6 of 6

Ingress protection	IP66 and IP68 (1MPa, 30 min)
--------------------	------------------------------

Ex marking: Ex e IIC Gb, Ex tD A20 IP66/68

- Producers should organize production in accordance with the technical documents approved by the certification body.

2. Specific conditions of safety use:

- By using the pressure screw without a clamping device only permanently wired cables may be entered. The user shall provide for the required strain relief.
- Degree of protection IP66 / IP68 will be safeguarded only when the cable glands are properly fitted. The manufacturer's instructions must be followed.
- Types with a low impact force shall be mounted into the enclosure in such a way that they are mechanically protected against impact force.
- The cable gland is installed in enclosures with through-holes or threaded holes. For through-holes, lock nuts are used.
- See instruction for other information.

3. Certificate related report(s):

- Type test report: CQST2011C056
- Factory inspection report: CN2021Q010004

4. Certificate change information: None

Issued on: 2022-01-19

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co., Ltd.

