



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312313000366

<b>Applicant</b>	Pflitsch GmbH & Co. KG
<b>Address</b>	Ernst-Pflitsch-Straße 1, 42499 Hückeswagen, Germany
<b>Manufacturer</b>	Pflitsch GmbH & Co. KG
<b>Address</b>	Ernst-Pflitsch-Straße 1, 42499 Hückeswagen, Germany
<b>Production Factory</b>	Pflitsch GmbH & Co. KG
<b>Production Address</b>	Ernst-Pflitsch-Straße 1, 42499 Hückeswagen, Germany
<b>Product</b>	Reducer
<b>Model/Type</b>	RED*****
<b>Ex marking</b>	Ex d IIC Gb, Ex e IIC Gb, Ex tD A20 IP66/68
<b>Reference Standards</b>	GB3836.1-2010, GB3836.2-2010, GB3836.3-2010, GB12476.1-2013, GB12476.5-2013

**Certification mode** Type Test + Initial Factory Inspection + Post-Certification Surveillance

The product(s) is verified and certified according to CNCA-C23-01: 2019 *China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product* and CNEC-C2301-2019 *Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product*.

See Annex for the detailed product information (4 pages).

Issued on: 2021-05-12

Valid to: 2026-05-11

The validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the original Chinese version, the Chinese version shall prevail.

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.



<http://www.ccc-cnex.com>  
[ccc.china-ex.com](http://ccc.china-ex.com)

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China P.C.: 473008  
Tel: 0377-63239734 Email: [ccc@cn-ex.com](mailto:ccc@cn-ex.com)

CN 0000641



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312313000366

Page 1 of 4

**Product information:**

1. This certificate covers the following models:

- RED\*\*\*\*\*

Nomenclature:

RED	*	*	*	*	*	*	*
1	2	3	4	5	6	7	8

1) Type

RED = Reducer

2) Type of connecting thread

2 = Metric

3 = NPT

3) Size of connecting thread (code number)

4) Size of second connecting thread of reducer (code number)

5) Material body

ms = brass

VA = stainless steel

6) EMC spring (optional)

- = no EMC spring

tri = with EMC spring

7) Explosion protection

Issued on: 2021-05-12

Director:



**Nanyang Explosion Protected Electrical  
Apparatus Research Institute Co.,Ltd.**





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

**No.:** 2021312313000366

Page 2 of 4

Ex d = Type of protection Flameproof enclosure "d"

8) Additional letter for material and O-ring

V4A = stainless steel

bl = brass blank

Technical data:

Size of thread	M16 to M63 NPT 3/8" to NPT 2 1/2"
Suited for devices of equipment group II with mechanical risk level	High, 7J
Mounted in enclosures with clearance holes(For Ex e, Ex tD) Plastic, wall thickness Metal, wall thickness	≥2mm ≥1mm
Mounted in enclosures with threaded holes(For Ex e, Ex tD) Plastic, wall thickness Metal, wall thickness	≥5mm ≥3mm
Torque see manual	Depending on the nominal size Metric, NPT: 15 Nm to 80 Nm
Ambient temperatures Connecting O-ring	Silicone -60 °C to +130 °C

Issued on: 2021-05-12

Director:



**Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.**





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312313000366

Page 3 of 4

Ingress protection	IP66, IP 68 (1h, 1MPa)
Service temperatures	-60 °C to +130 °C

Thread, metric	Thread, NPT	Torque	Min. Temperature, Overpressure
M16×1.5	NPT 3/8"	15 Nm	-60 °C / 4.86MPa
M20×1.5	NPT 1/2"	20 Nm	-60 °C / 4.86MPa
M25×1.5	NPT 3/4"	30 Nm	-60 °C / 4.86MPa
M32×1.5	NPT 1"	30 Nm	-60 °C / 4.86MPa
M40×1.5	NPT 1 ¼"	35 Nm	-60 °C / 4.86MPa
M50×1.5	NPT 2"	80 Nm	-60 °C / 4.86MPa
M63×1.5	NPT 2 ½"	80 Nm	-60 °C / 4.86MPa

Ex marking: Ex d IIC Gb, Ex e IIC Gb, Ex tD A20 IP66/68

- Producers should organize production in accordance with the technical documents approved by the certification body.
- 2. Specific conditions of safety use:
  - When the reducer is built into an enclosure in the type of protection Flameproof enclosure "d", it is recommended to include them into the explosion tests of enclosure.
  - See instruction for other information.

Issued on: 2021-05-12

Director:



**Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.**





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312313000366

Page 4 of 4

3. Certificate related report(s):
  - Type test report: CQST2011C049
  - Factory inspection report: CN2021Q010004
4. Certificate change information: None

Issued on: 2021-05-12

Director:



Nanyang Explosion Protected Electrical  
Apparatus Research Institute Co.,Ltd.

