



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312313000367

Applicant Pflitsch GmbH & Co. KG
Address Ernst-Pflitsch-Straße 1, 42499 Hückeswagen, Germany
Manufacturer Pflitsch GmbH & Co. KG
Address Ernst-Pflitsch-Straße 1, 42499 Hückeswagen, Germany
Production Factory Pflitsch GmbH & Co. KG
Production Address Ernst-Pflitsch-Straße 1, 42499 Hückeswagen, Germany
Product Blind plug
Model/Type BSM*****
Ex marking Ex d IIC Gb, Ex e IIC Gb, Ex tD A20 IP66/68
Reference Standards GB3836.1-2010, GB3836.2-2010, GB3836.3-2010,
GB12476.1-2013, GB12476.5-2013

Certification mode Type Test + Initial Factory Inspection + Post-Certification Surveillance

The product(s) is verified and certified according to CNCA-C23-01: 2019 *China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product* and CNEX-C2301-2019 *Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product*.

See Annex for the detailed product information (3 pages).

Issued on: 2021-05-12

Valid to: 2026-05-11

The validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the original Chinese version, the Chinese version shall prevail.

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.



<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China
Tel: 0377-63239734

P.C.: 473008
Email: ccc@cn-ex.com

CN 0000642



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312313000367

Page 1 of 3

Product information:

1. This certificate covers the following models:

- BSM*****

Nomenclature:

BSM	*	*	*	*	*
1	2	3	4	5	6

- 1) Type
BSM = Blind plug
- 2) Type of connecting thread
2 = Metric
3 = NPT
- 3) Size of connecting thread (code number)
- 4) Material body
ms = brass
VA = stainless steel
- 5) Explosion protection
Ex d = Type of protection Flameproof enclosure "d"
- 6) Additional letter for material and O-ring
V4A = stainless steel
bl = brass blank

Technical data:

Size of thread	M16 to M63 NPT 3/8" to NPT 2 1/2"
----------------	--------------------------------------

Issued on: 2021-05-12

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312313000367

Page 2 of 3

Suited for devices of equipment group II with mechanical risk level	High, 7J
Mounted in enclosures with clearance holes (For Ex e, Ex tD)	
Plastic, wall thickness	≥2mm
Metal, wall thickness	≥1mm
Mounted in enclosures with threaded holes (For Ex e, Ex tD)	
Plastic, wall thickness	≥5mm
Metal, wall thickness	≥3mm
Torque see manual	Depending on the nominal size Metric, NPT: 15 Nm to 80 Nm
Ambient temperatures	
Connecting O-ring	Silicone -60 °C to +130 °C
Ingress protection	IP66, IP 68 (1h, 1MPa)
Service temperatures	-60 °C to +130 °C

Issued on: 2021-05-12

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co., Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2021312313000367

Page 3 of 3

Thread, metric	Thread, NPT	Torque	Min. Temperature, Overpressure
M16×1.5	NPT 3/8"	15 Nm	-60 °C / 4.86MPa
M20×1.5	NPT 1/2"	20 Nm	-60 °C / 4.86MPa
M25×1.5	NPT 3/4"	30 Nm	-60 °C / 4.86MPa
M32×1.5	NPT 1"	30 Nm	-60 °C / 4.86MPa
M40×1.5	NPT 1 ¼"	35 Nm	-60 °C / 4.86MPa
M50×1.5	NPT 2"	80 Nm	-60 °C / 4.86MPa
M63×1.5	NPT 2 ½"	80 Nm	-60 °C / 4.86MPa

Ex marking: Ex d IIC Gb, Ex e IIC Gb, Ex tD A20 IP66/68

- Producers should organize production in accordance with the technical documents approved by the certification body.
- 2. Specific conditions of safety use:
 - When the blind plug is built into an enclosure in the type of protection Flameproof enclosure "d", it is recommended to include them into the explosion tests of enclosure.
 - See instruction for other information.
- 3. Certificate related report(s):
 - Type test report: CQST2011C051
 - Factory inspection report: CN2021Q010004
- 4. Certificate change information: None

Issued on: 2021-05-12

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.

