

# **Certificate of Compliance**

| Certificate: | 1247791   | Master Contract: | 212887     |
|--------------|---|------------------|------------|
| Project:     | 80047197  | Date Issued:     | 2020-06-30 |
| Issued To:   | Pflitsch GmbH & Co. KG<br>Ernst-Pflitsch-Str. 1 |                  |            |

Huckeswagen, Nordrhein-Westfalen, 42499 Germany

Attention: Benno Sassenbach

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Michael Chung Issued by: Michael Chung

#### **PRODUCTS**

CLASS 4414 08 - FITTINGS Cable - Hardware CLASS 4414 88 - FITTINGS Cable - Hardware - Certified to US Standards

Fittings for flexible cords, liquid tight type 3 enclosure outdoor use, for use with one or multiple cords:

| <u>Cat No</u> .    | Series .     | Type .    | Cord Diameters |
|--------------------|--------------|-----------|----------------|
| UNI Dicht          | U2           | 1 X d p Y | 4.0 to 44.0 mm |
| UNI Dicht          | U2.Metrisch  | 2 X d p Y | 4.0 to 44.0 mm |
| UNI Dicht          | U12          | 1 X u p Y | 4.0 to 44.0 mm |
| UNI Dicht          | U12.Metrisch | 2 X u p Y | 4.0 to 44.0 mm |
| UNI Dicht Multiple | U7.Metrisch  | 2 X d m Y | 3.0 to 13.0 mm |
| UNI Dicht Multiple | U16          | 1 X u m Y | 1.5 to 13.0 mm |
| UNI Dicht Multiple | U16.Metrisch | 2 X u m Y | 1.5 to 13.0 mm |
| UNI Entstör        | U4           | 1 X e p Y | 8.0 to 13.0 mm |
| UNI Entstör        | U4.Metrisch  | 2 X e p Y | 6.0 to 12.0 mm |

#### **APPLICABLE REQUIREMENTS**

| CSA Std. C22.2 No. | 18.3-12, 2 <sup>nd</sup> Ed - Conduit, Tubing, and Cable Fittings |
|--------------------|---|
| UL Std. No.        | 514B, 6 <sup>th</sup> Ed - Conduit, Tubing, and Cable Fittings    |



## Supplement to Certificate of Compliance

Certificate: 1247791

Master Contract: 212887

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

### **Product Certification History**

| Project  | Date       | Description  |
|----------|------------|--|
| 80047197 | 2020-06-30 | One alternate plastic and two alternate metallic housing material.   |
| 70037173 | 2015-10-01 | Update to report - 1247791 Gasket of U12-series: Color: "Transparent" must be substituted by "nature". Gasket of U2-series: Material: #Silicone (Silopren LSR), Recognized (E205753)# must be substituted by "provided with rubber O-ring". Gasket of U4-series: Material: #Silicone (Silopren LSR), recognized (E205753)# must be substituted by "provided with rubber O-ring". Update to latest version of Standard. Under assumption that no tests are necessary. |
| 1376483  | 2002-02-27 | Add Series U7.Metrisch.  |
| 1262144  | 2001-11-13 | Add Series U2.Metrisch, U4, U12.Metrisch, U16.Metrisch.  |
| 1247791  | 2001-06-21 | Original Certification Series U2, U12, U16.  |